



Wealden Homes
Wealden Court
Church Street
Teston
Kent
ME18 5AG

QTS Environmental Ltd
Unit 1
Rose Lane Industrial Estate
Rose Lane
Lenham Heath
Kent
ME17 2JN
t: 01622 850410
russell.jarvis@qtsenvironmental.com

QTS Environmental Report No: 16-48853

Site Reference: Laddingford

Project / Job Ref: None Supplied

Order No: None Supplied

Sample Receipt Date: 06/09/2016

Sample Scheduled Date: 07/09/2016

Report Issue Number: 1

Reporting Date: 12/09/2016

Authorised by:

A handwritten signature in black ink, appearing to read 'R Jarvis'.

Russell Jarvis
Associate Director of Client Services

Authorised by:

A handwritten signature in black ink, appearing to read 'Ela Mysiara'.

Ela Mysiara
Inorganics & ICP Section Head



QTS Environmental Ltd
Unit 1, Rose Lane Industrial Estate
Rose Lane
Lenham Heath
Maidstone
Kent ME17 2JN
Tel : 01622 850410



Bulk Analysis Certificate						
QTS Environmental Report No: 16-48853	Date Sampled	None Supplied	None Supplied	None Supplied		
Wealden Homes	Time Sampled	None Supplied	None Supplied	None Supplied		
Site Reference: Laddingford	TP / BH No	LADD 1	LADD 2	LADD 3		
Project / Job Ref: None Supplied	Additional Refs	Main Workshop (On Left When Entering Site)	Building Midway Down Site	Office/Welfare (On Right When Entering)		
Order No: None Supplied	Depth (m)	None Supplied	None Supplied	None Supplied		
Reporting Date: 12/09/2016	QTSE Sample No	226261	226262	226263		

Determinand	Unit	RL	Accreditation				
Asbestos Type	PLM Result	N/a	ISO17025	Chrysotile	Chrysotile	Chrysotile	
Sample Matrix	Material Type	N/a	NONE	Cement type material	Cement type material	Cement type material	

The samples have been examined to identify the presence of asbestiform minerals by polarising light microscopy and dispersion staining technique to In-House Procedures QTSE600 Determination of Asbestos in Bulk Materials; Asbestos in Soils/Sediments (fibre screening and identification) that is in accordance with the Health and Safety Executive HSG 248 Appendix 2.

This report refers to samples as received, and QTS Environmental Ltd, takes no responsibility for the accuracy or competence of sampling by others.

The material description shall be regarded as tentative and is not included in our scope of UKAS Accreditation.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

Asbestos Analyst: Graham Revell

RL: Reporting Limit