



DOVER DISTRICT COUNCIL

22 FEB 2016

PLANNING SECTION

Planning Section  
Dover District Council  
Head Office  
White Cliffs Business Park  
Dover  
Kent  
CT16 3PJ

Developer Services  
Southern Water  
Sparrowgrove House  
Sparrowgrove  
Otterbourne  
Hampshire  
SO21 2SW

Tel: 0330 303 0119

Email: [developerservices@southernwater.co.uk](mailto:developerservices@southernwater.co.uk)

Your Ref

DOV/16/00007

Our Ref

PLAN-012766

Date

18/02/2016

Dear Sir

**Proposal: Erection of 2no. semi-detached dwellings with integral carports and attached private garage; erection of 1no. attached dwelling; conversion of existing ground floor shop into a self-contained flat, and associated parking and landscaping(existing garages to be demolished).**

**Site: Land and Garages rear of and including 4 & 5, The Droveaway, St. Margaret's Bay, CT15 6DH.**

**DOV/16/00007**

Thank you for your letter of 29/01/2016.

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development. To initiate a sewer capacity check to identify the appropriate connection point for the development, Please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or [www.southernwater.co.uk](http://www.southernwater.co.uk)".

Our initial investigations indicate that there are no public surface water sewers in the area to serve this development. Alternative means of draining surface water from this development are required. This should not involve disposal to a public foul sewer.

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of foul and surface water sewerage disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water."

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or [www.southernwater.co.uk](http://www.southernwater.co.uk)".

Yours sincerely

A black rectangular box redacting the signature of the person sending the letter.

Developer Services