



Nisha Mistry BWB Consulting 6th Floor Livery Place 35 Livery Street Birmingham B3 2PB Your ref

Our ref DS CC PDE-116260

Date

19 February 2021

Contac

Tel 0330 303 0119

Dear Ms Mistry,

Level 1 Capacity Check Enquiry: Land off Sandwich Road, Deal, Dover, Kent, CT14 0AB.

We have completed the capacity check for the above development site and the results are as follows:

Foul Water

The enquiry has been reassessed to determine the maximum capacity available for foul water flow at manhole references TR35514801, TR35515901 or TR35524601.

There is currently adequate capacity in the local sewerage network to accommodate a foul flow of no greater than **1.5** I/s for the above development at either of manhole references TR35514801 or TR35515901. In addition, manhole TR35524601 can accommodate a foul flow of no greater than **0.50** I/s. Please note that no surface water flows (existing or proposed) can be accommodated within the existing foul sewerage system unless agreed by the Lead Local Flood Authority in consultation with Southern Water, after the hierarchy Part H3 of Building Regulations has been complied with.

Connecting to our network

It should be noted that this information is only a hydraulic assessment of the existing sewerage network and does not grant approval for a connection to the public sewerage system. A formal Sewer Connection (S106) application is required to be completed and approved by Southern Water Services. To make an application visit: <u>Developer Services Portal (southernwater.co.uk)</u>

Please note the information provided above does not grant approval for any designs/drawings submitted for the capacity analysis. The results quoted above are only valid for 12 months from the date of issue of this letter.

Should it be necessary to contact us please quote our above reference number relating to this application by email at southernwater.co.uk

Yours sincerely,

Joff Edevane

Growth Planning Lead

Dule

Business Channels